

NOTICE OF DRINKING WATER GROSS ALPHA PARTICLE ACTIVITY VIOLATION

The Texas Commission on Environmental Quality notified the City of Mason Water System that drinking water supplied to customers exceeds the Maximum Contaminant Level (MCL) for GROSS ALPHA. The US Environmental protection Agency set the MCL for GROSS ALPHA at 15 pico Curies per liter (pCi/L) and had determined a health concern exists at levels above the MCL. Analysis of drinking water in your community for Gross Alpha indicated a level of 17.0 pCi/L. This is not an emergency. However, some people who drink water containing Gross Alpha in excess of the MCL over many years may have an increased risk of getting cancer. You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you. We are working to correct the problem by studying the feasibility of limiting the use of certain wells to lower Gross Alpha contamination and by considering the purchase of an additional drinking water well which may reduce Gross Alpha contamination. Please share this information with all other people who may not have received this notice directly (for example people in apartments, nursing homes, schools and businesses). Do this by posting this notice in a public place or distributing it by hand or mail. For more information contact Joe Martinez at 325.347.6449. Public Water System ID# 1600001

EL AVISO DE LA VIOLACIÓN GRUESA de la ACTIVIDAD de la PARTÍCULA ALFA del AGUA POTABLE

La Comisión de Tejas en calidad ambiental notificó a la ciudad del sistema del agua de Masón que el agua potable proveída a los clientes excede el nivel máximo del contaminante (MCL) para la ALFA GRUESA. La agencia de protección del medio ambiente de los E.E.U.U. fijó el MCL para la ALFA GRUESA en 15 curies del pico por el litro (pCi/L) y había determinado una preocupación de la salud existe en los niveles sobre el MCL. El análisis del agua potable en su comunidad para la alfa gruesa indicó un nivel de 17.0 pCi/L. Esto no es una emergencia. Sin embargo, alguna gente que bebe alfa gruesa con agua superior al MCL sobre muchos años puede tener un riesgo creciente de conseguir el cáncer. Usted no necesita utilizar un abastecimiento de agua alternativo. Sin embargo, si usted tiene preocupaciones de la salud, usted puede desear hablar con su doctor para conseguir más información sobre cómo ésto puede afectarle. Estamos trabajando para corregir el problema estudiando la viabilidad de limitar el uso de ciertos pozos de bajar la contaminación gruesa de la alfa y considerando la compra de un pozo adicional del agua potable que pueda reducir la contaminación gruesa de la alfa. Comparta por favor esta información con el resto de la gente que pudo no haber recibido este aviso directamente (por ejemplo gente en apartamentos, clínicas de reposo, escuelas y negocios). Haga esto fijando este aviso en un lugar público o distribuyéndolo a mano o envíelo. Para más información puede hacer contacto con Joe Martinez a numero de telefono 325.347.6449. Sistema público ID# 1600001 del agua